

**Kent County Department of Public Works
Division of Water & Wastewater Services**

Edesville Sub-District

PWSID: 014-0009

Disinfectants and Disinfection By-Products	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine (2020)	0.5	0.3 – 0.5	MRDLG= 4	MRDL=4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5) (2020)	9.0	9 – 9	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM) (2020)	39.1	39.1 – 39.1	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

If you should have any questions regarding this report or concerning your water utility, please contact Kent County Department of Public Works Division of Water and Wastewater Services, at 410-778-3287. In addition, any resident may obtain a copy of this report at the main office Monday thru Friday during normal business hours or on the internet at <https://www.kentcounty.com/water/reports>.